

MEPNN Supplier Scouting Opportunity Synopsis

Section 1: General Information

Scouting Number	2026-127
Item to be Scouted	BABA-Compliant Mini-Splits (HVAC)
Days to be scouted	14
Response Due By	04/29/2026
Description	This is for a federally-funded housing project in Montana. We are seeking four BABA-compliant Mini-Split HVAC units, functionally equivalent to a Daikin ETYE18 V III

Section 2: Technical Information

Type of supplier being sought	Manufacturer
Reason	BABA
Describe the manufacturing processes (elaborate to provide as much detail as possible)	Mechanical/Electronic/Electrical Assembly
Provide dimensions / size / tolerances / performance specifications for the item	Inside Unit: High wall, 4-speed airflow, Volt/Phase 208/1, FLA 0.2 Outside Unit: COOLING: capacity 18 MBH, SEER2 21, HEATING; capacity @47F 21.6, HSPF 9.6, ELECTRIC Volt/Phase 208/1, FLA 9.31, MOP 20, Max dB 54, R-32 refrigerant, incl all piping, valves and accessories. Heat operating range 5F-65F See the attachment for full specifications.
List required materials needed to make the product, including materials of product components	Various as required for implementation.
Are there applicable certification requirements?	No
Are there applicable regulations?	No
Are there any other standards, requirements, etc.?	No
Additional Technical Comments	

Section 4: Business Information

Estimated potential business volume	4 units
Estimated target price / unit cost information (if unavailable explain)	depends on if we can find BABA-compliant units.
When is it needed by?	Summer 2026
Describe packaging requirements	Deliver undamaged
Where will this item be shipped?	Montana

Additional Comments

Is there other information you would like to include?	
---	--